

Section 1 – Electrical Bridging Details	
Bridging Permit Number	
Bridging Type Mechanical or Electrical component	
Location	
Programmable Logic Controller Bit Forced	
Diagram Number	
Drawing Reference Number	
Bridge Justification A bridge can only be used for a maximum of 24 hours unless extenuating circumstances and agreed by a manager. The bridge then needs to be reviewed.	
Safety Functionality	
Hazard Identification and <i>Risk Analysis</i> Electrical safety devices are not permitted to be bypassed and no live work is permitted. (As per <i>Energy Safety Regulations</i> prohibition of live work)	A risk assessment must be completed by an authorised, competent, and licensed person, advising the steps to be taken to ensure all protection to personnel and plant is maintained.
Comments	
☐ Copy to Terminal Superintendent. ☐ Copy to Maintenance Superintendent. ☐ Copy to be kept in Control Room.	
Section 2 – Supervisor and Electrical Supervisor Approval	
Supervisor	
	Signature _____ Date _____
Electrical Supervisor	
	Signature _____ Date _____
	Called _____ Time _____
Section 3 – Electrical Bridging Placement	
Bridge Placed by	
	Signature _____ Date _____
Section 4 – Electrical Bridging Removal	
Bridge Removed by	
	Signature _____ Date _____